Annual Drinking Water Quality Report for 2025
TOWN OF SENECA WD #1
3675 Flint Road, Stanley, New York 14561
(Public Water Supply ID# 3401178)

INTRODUCTION

To comply with State regulations, the Town of Seneca will be annually issuing a report describing the quality of your drinking water. The purpose of this report is to raise your understanding of drinking water and awareness of the need to protect our drinking water sources. Last year, your tap water met all State drinking water health standards. We are proud to report that our system did not violate a maximum contaminant level or any other water quality standard. This report provides an overview of last year's water quality. Included are details about where your water comes from, what it contains, and how it compares to State standards.

If you have any questions about this report or concerning your drinking water, please contact **Ben Karlsen, Water Superintendent, at 585-526-6888 Ext.2035.** We want you to be informed about your drinking water. If you want to learn more, please attend any of our regularly scheduled Town board meetings. The meetings are held in the Town Hall located at 3675 Flint Road, Stanley, on **every third Tuesday of the month at 7:30 P.M.**

WHERE DOES OUR WATER COME FROM?

In general, the sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activities. Contaminants that may be present in source water include microbial contaminants; inorganic contaminants; pesticides and herbicides; organic chemical contaminants; and radioactive contaminants. In order to ensure that tap water is safe to drink, the State and the EPA prescribe regulations which limit the amount of certain contaminants in water provided by public water systems. The State Health Department's and the FDA's regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Our water is purchased from the Town of Geneva whose source consists of four drilled wells located at Kashong. Well #3 is their primary source with Wells #1 and #2 and #4 used as a back up during periods of increased demand. During 2025, our system did not experience any restriction of our water source. The Town of Geneva treats the ground water in a variety of ways prior to entering distribution. The water is disinfected through the use of chlorine. Fluoride is added to the water for the promotion of healthy teeth and gums and orthophosphate is used for corrosion control purposes prior to distribution.

FACTS AND FIGURES

Our water system serves 2,720 people through 1,168 service connections. The total water purchased in 2025 was 293,763,000. The daily average of water treated and pumped into the distribution system was 804,830 gallons per day. Our highest single day was 1,238,295 gallons. The amount of water delivered to customers was 271,839,227. This leaves an unaccounted-for total of 21,923,773 gallons. This is approximately 7.46% of the total purchased and is attributed to the flushing of mains, firefighting, and leakage. In 2025, water customers were charged per quarter $50.00 for the first 6,000 gallons and $4.75 per thousand gallons above 6,000 gallons. For the average family using 18,000 gallons per quarter, the cost of purchasing water was $428.00 annually in 2025. This equates to an annual charge of $5.95 per 1,000 gallons used or about $1.17 cents per day.

ARE THERE CONTAMINANTS IN OUR DRINKING WATER?

As the State regulations require, we routinely test your drinking water for numerous contaminants. These contaminants include total coliform, inorganic compounds, nitrate, lead and copper, volatile organic compounds, and total trihalomethanes. The table presented below depicts which compounds were detected in your drinking water. The State allows us to test for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though representative, are more than one year old.

It should be noted that all drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline (800-426-4791) or the New York State Department of Health (Geneva District Office) at 315-789-3030.

The NYS DOH has completed a source water assessment for this system, based on available information. Possible and actual threats to this drinking water source were evaluated. The state source water assessment

includes a susceptibility rating based on the risk posed by each potential source of contamination and how easily contaminants can move through the subsurface to the wells. The susceptibility rating is an estimate of the potential or contamination of the source water, it does not mean that the water delivered to consumers is, or will become contaminated. See section "Are there contaminants in our drinking water?" for a list of the contaminants that have been detected. The source water assessments provide resource managers with additional information for protecting source waters into the future.

As mentioned before, our water is derived from 4 drilled wells. The source water assessment has rated these wells as having a medium-high susceptibility to microbials, nitrates, metals, herbicides and pesticides, petroleum products, halogenated solvents, and other industrial contaminants. Susceptibility to enteric viruses was found to be high. These ratings are due primarily to the close proximity of residential development to the wells, and that the wells draw from an unconfined aquifer with high hydraulic conductivity. While nitrates (and other inorganic contaminants) were detected in our water, it should be noted that all drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some contaminants from natural sources. The presence of contaminants does not necessarily indicate that the water poses a health risk. Please note that, while the source water assessment rates our well as being susceptible to microbials, our water is disinfected to ensure that that the finished water delivered into your home meets the New York State drinking water standards for microbial contamination.

County and state health departments will use this information to direct future source water protection activities. These may include water quality monitoring, resource management, planning, and education programs. A copy of the assessment, including a map of the assessment area, can be obtained by contacting us, as noted below.

Table of Detected Contaminants

Contaminant	Violation	Date of Sample	Level Detected (Avg/Max) (Range)	Unit Measurement	MCLG	Regulatory Limit (MCL, TT or AL)	Likely Source of Contamination
Inorganic Contaminants							
Nitrate	NO	8/14/25	1.4	Mg/l	10	MCL = 10	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.
Barium	NO	7/28/2022	73.6	Ug/l	2	MCL = 2000	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.
Fluoride	NO	Monthly 2025	0.77 (0.6 – 0.9)	Mg/l	N/A	MCL = 2.2	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories.
Sodium	NO	8/14/2025	38.2	Mg/l	0	No Designated Limits ***	Naturally occurring, road salt, water softeners and animal waste.
Copper	NO	8/2024	1120 (20.2-1430)	ug/l	1300	AL = 1300	Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives.
Lead	NO	8/2024	2.1 (0-5.2)	Ug/l	15	AL = 15	Corrosion of household plumbing systems; erosion of natural deposits.
Pfos/Pfoa	NO	Aug 2025	<1.0	ng/l	N/A	Ng/l=10	Released into environment from widespread use commercial and industrial applications.

Volatile Organic Contaminants							
THM's (trihalomethanes)	NO	8/6/2025 Stage 2	42.5** (46 – 39)	Ug/l	0	MCL = 80	A byproduct of drinking water disinfection, needed to kill harmful organisms.
HAA5 (haloacetic acids)	NO	8/6/2025 Stage 2	12.5** (14 – 11)	Ug/l	0	MCL = 60	A byproduct of drinking water disinfection, needed to kill harmful organisms.
Radiological Contaminants							
Gross Alpha	NO	8/10/2023	1.87 +/ -0.945	pCi/L	0	MCL = 5	Erosion of natural deposits.
Radium 226	NO	8/10/2023	0.256 +/ - 0.354	pCi/L	0	MCL = 5	Erosion of natural deposits.
Radium 228	NO	8/10/2023	0.323 +/ - 0.384	pCi/L	0	MCL = 5	Erosion of natural deposits.

Notes: * The level presented represents the 90th percentile of the 20 sites tested. A percentile is a value on a scale of 100 that indicates the percent of a distribution that is equal to or below it. The 90th percentile is equal to or greater than 90% of the copper values detected at your water system. In this case, 20 samples were collected at your water system and the 90th percentile value was the third highest value. The action level for copper was not exceeded at any of the sites tested. The action level for lead was not exceeded at any of the sites tested. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

* The action level for lead wasn't exceeded at any of the sites. The action level for copper was exceeded at one of the sites.

** THM/HAA5 levels represents the highest locational running annual average calculated from data collected.

*** Water containing more than 20 mg/L of sodium should not be used for drinking by people on severely restricted sodium diets. Water containing more than 270 mg/L of sodium should not be used for drinking by people on moderately restricted sodium diets.

The Town of Seneca is required to collect and analyze a minimum of three, (3), total coliform samples from various points within the town each month. The table below summarizes total coliform testing for 2025.

Parameter	EPA/NYS Limits	Units	Low	High	Violations	Samples in 2025
Coliform (see notation below)	*	colonies/100ml	NEG	Present	No	36
E. Coli	*		NEG		No	36

* = a violation occurs when two or more samples a month are total coliform positive.

Total Coliforms – Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present.

Fecal Coliform/E. Coli – Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, and people with severely compromised immune systems.

Definitions:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contamination.

Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Level 1 Assessment: A Level 1 assessment is an evaluation of the water system to identify potential problems and determine, if possible, why total coliform bacteria have been found in our water system.

Level 2 Assessment: A Level 2 assessment is an evaluation of the water system to identify potential problems and determine, if possible, why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

Non-Detects (ND): Laboratory analysis indicates that the constituent is not present.

Nephelometric Turbidity Unit (NTU): A measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Milligrams per liter (mg/l): Corresponds to one part of liquid in one million parts of liquid (parts per million - ppm).

Micrograms per liter (ug/l): Corresponds to one part of liquid in one billion parts of liquid (parts per billion - ppb).

Nanograms per liter (ng/l): Corresponds to one part of liquid to one trillion parts of liquid (parts per trillion - ppt).

Picograms per liter (pg/l): Corresponds to one part per of liquid to one quadrillion parts of liquid (parts per quadrillion – ppq).

Picocuries per liter (pCi/L): A measure of the radioactivity in water.

Millirems per year (mrem/yr): A measure of radiation absorbed by the body.

Million Fibers per Liter (MFL): A measure of the presence of asbestos fibers that are longer than 10 micrometers.

WHAT DOES THIS INFORMATION MEAN?

As you can see by the table, our system had no violations. We have learned through our testing that some contaminants have been detected; however, these contaminants were detected below the level allowed by the State.

IS OUR WATER SYSTEM MEETING OTHER RULES THAT GOVERN OPERATIONS?

Our water system was in compliance with applicable State drinking water operating, monitoring and reporting requirements. The Town of Seneca is required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not your drinking water meets health standards.

INFORMATION ON FLUORIDE ADDITION

Our system is one of the many drinking water systems in New York State that provides drinking water with a controlled, low level of fluoride for consumer dental health protection. Fluoride is added to your water by the Town of Geneva before it is delivered to us. According to the United States Centers for Disease Control, fluoride is very effective in preventing cavities when present in drinking water at a properly controlled level. To ensure that the fluoride supplement in your water provides optimal dental protection, the State Department of Health requires that the Town of Geneva monitor fluoride levels on a daily basis. During 2025 monitoring showed fluoride levels in your water were in the optimal range 100% of the time. None of the monitoring results showed fluoride at levels that approach the 2.2 mg/l MCL for fluoride.

INFORMATION ON LEAD

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Town of Seneca Water District #1 is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share

the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Town of Seneca Water Department at 585-526-6888 Ext.2035. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at *http://www.epa.gov/safewater/lead*.

INFORMATION ON LEAD SERVICE LINE INVENTORY

The Town of Seneca has completed its Lead Service Line Inventory. We are proud to say that No lead service lines have been found in the town's service area. A copy of that report can be found on the Town of Seneca website.

SYSTEM IMPROVMENTS

In 2024 the Town of Seneca made improvements to our system storage by adding another 1.5 million gallon concrete storage tank at the property on Olsen Rd. This allows us to have more storage capacity for future expansion and higher demands for years to come. We also had the 1 million gallon steel storage tank at the property on Kashong Switch Rd. reconditioned as well as the pressure reducing valve relocated to an above ground hot box instead of the underground pit.

DO I NEED TO TAKE SPECIAL PRECAUTIONS?

Although our drinking water met or exceeded state and federal regulations, some people may be more vulnerable to disease causing microorganisms or pathogens in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care provider about their drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium, Giardia and other microbial pathogens are available from the Safe Drinking Water Hotline (800-426-4791).

WHY SAVE WATER AND HOW TO AVOID WASTING IT?

Although our system has an adequate amount of water to meet present and future demands, there are a number of reasons why it is important to conserve water:

- Saving water saves energy and some of the costs associated with both of these necessities of life;
- Saving water reduces the cost of energy required to pump water and the need to construct costly new wells, pumping systems and water towers; and
- Saving water lessens the strain on the water system during a dry spell or drought, helping to avoid severe water use restrictions so that essential firefighting needs are met.

You can play a role in conserving water by becoming conscious of the amount of water your household is using, and by looking for ways to use less whenever you can. It is not hard to conserve water. Conservation tips include:

- Automatic dishwashers use 15 gallons for every cycle, regardless of how many dishes are loaded. So get a run for your money and load it to capacity.
- Turn off the tap when brushing your teeth.
- Check every faucet in your home for leaks. Just a slow drip can waste 15 to 20 gallons a day. Fix it and you can save almost 6,000 gallons per year.
- Check your toilets for leaks by putting a few drops of food coloring in the tank, watch for a few minutes to see if the color shows up in the bowl. It is not uncommon to lose up to 100 gallons a day from one of these otherwise invisible toilet leaks. Fix it and you save more than 30,000 gallons a year.
- Use your water meter to detect hidden leaks. Simply turn off all taps and water using appliances, then check the meter after 15 minutes. If it moved, you have a leak.

CLOSING

Thank you for allowing us to continue to provide your family with quality drinking water this year. In order to maintain a safe and dependable water supply we sometimes need to make improvements that will benefit all of our customers. The costs of these improvements may be reflected in the rate structure. Rate adjustments may be necessary in order to address these improvements. We ask that all our customers help us protect our water sources, which are the heart of our community. For questions regarding the content of the report, please contact Ben Karlsen at the Town of Seneca (585) 526-5251 Ex. 2035 or the NYSDOH at (315) 789-3030.